

DRAWINGS

AS- BUILT STRUCTURES


PASABAND, GHOR, AFGHANISTAN

Identified Gaps in Existing WASH Services in Shinkot CHC:

- The building has plumbing system and waste water drain system, but the systems are damaged need to fundamental repairing.
- The existing toilets are damaged (floor tiles are broken, there is no flush tanks and there is not any stand WC for disabled people).
- The septic tank slab is broken and there is no drain pit next to the septic tank.
- There is hand washing sinks in the clinic rooms, but they are not connected to the water supply and drain system.
- The clinic doors are made of PVC material but the handles are damaged and they face problems during opening doors especially in the delivery room.
- There is no hand washing station in the clinic area

Solution:

- ActionAid plans to repair the water supply and waste water systems by connecting the hot and cold water from the water sources to the sinks and flush tanks and directing the waste water to the septic tank
- Rehabilitation of existing toilets by demolishing the floor by renewing the floors with new tiles and installing 2 stand WC's for male and other to female section for disabled people.
- Construction of the septic tank slab, drilling the drain pit and connecting of waste water to the septic tank.
- Connection of the hand washing sinks to the cold and hot water sources.
- Installation of the handles for the PVC doors.
- construction one public tap-station in clinic area for location and details (drawing)

TASK & RESPONSIBILITIES		DATE	NO OF PAGES 	PROVINCE	Ghor	SCALE	-	PROJECT SUB TITLE	Major maintenance of HCF WASH-Sector
SURVEYED BY	Gh. Farooq Ghafoori	23-05-2024		DISTRICT	Pasaband	START DATE	-	DRAWING TYPE	-
DRAWN BY	Gh. Farooq Ghafoori	04-06-2024		HCF NAME	Shinkot	END DATE	-	E	64° 51' 4.78"
REVIEWED BY	Hekmatullah Arefzai	-		HCF TYPE	CHC	PROJECT TITLE	FCDO-DAWAM	N	33° 41' 34.65"
APPROVED BY	Simon Wankuru	-							







TABLE OF CONTENT	
1	Shinkot CHC building
2	Bore Well
3	Elevated Water Tank
4	Generator Room
5	Guard Room
6	Main Door
7	Dry Latrine
8	Septic Tank
9	Toilets
10	Incinerator
11	New Tap-Station

SHINKOT CHC SITE PLAN



	TASK & RESPOSIBILITIES		DATE	<div>26</div>	PROVINCE	Ghor	SCALE	1:200	PROJECT SUB TITLE	Major maintenance of HCF WASH-Sector
	SURVEYED BY	Gh. Farooq Ghafoori	23-05-2024		DISTRICT	Pasaband	START DATE	----	DRAWING TYPE	Site Plan
	DRAWN BY	Gh. Farooq Ghafoori	04-06-2024		HCF NAME	Shinkot	END DATE	----	E	64° 51' 4.78"
	REVIEWED BY	Hekmatullah Arefzai	-		HCF TYPE	CHC	PROJECT TITLE	FCDO-DAWAM	N	33° 41' 34.65"
	APPROVED BY	Simon Wankuru	-							



SHINKOT CHC MAIN BUILDING TILE AND CERAMIC PLAN


Note:

- All dimension are in cm, unless otherwise noted



- The floor drains, tabs and toilets need water supply system and waste water systems need to be connected to the water tank and septic tank




TASK & RESPOSIBILITIES		DATE	NO OF PAGES <div>3 6</div>	PROVINCE	Ghor	SCALE	1:100	PROJECT SUB TITLE	Major maintenance of HCF WASH-Sector
SURVEYED BY	Gh. Farooq Ghafoori	23-05-2024		DISTRICT	Pasaband	START DATE	----	DRAWING TYPE	Building Plan
DRAWN BY	Gh. Farooq Ghafoori	04-06-2024		HCF NAME	Shinkot	END DATE	----	E	64° 51' 4.78"
REVIEWED BY	Hekmatullah Arefzai	-		HCF TYPE	CHC	PROJECT TITLE	FCDO-DAWAM	N	33° 41' 34.65"
APPROVED BY	Simon Wankuru	-							




RCC Cover For Manhole



SHINKOT CHC EXISTING SEPTIC TANK PLAN



SECTION A-A





SEPTIC TANK BEAM AND SLAB BAR BENDING DETAIL

Note:


- All dimension are in cm, unless otherwise noted
- The existing septic tank slab is damaged need to be repairing according to Engineer's guide
- For the septic tank location in the clinic site refers to site plan reference #8

act:onaïd


TASK & RESPOSIBILITIES		DATE	NO OF PAGES 	PROVINCE	Ghor	SCALE	1:100	PROJECT SUB TITLE	Major maintenance of HCF WASH-Sector
SURVEYED BY	Gh. Farooq Ghafoori	23-05-2024		DISTRICT	Pasaband	START DATE	----	DRAWING TYPE	Septic tank paln & section
DRAWN BY	Gh. Farooq Ghafoori	04-06-2024		HCF NAME	Shinkot	END DATE	----	E	64° 51' 4.78"
REVIEWED BY	Hekmatullah Arefzai	-		HCF TYPE	CHC	PROJECT TITLE	FCDO-DAWAM	N	33° 41' 34.65"
APPROVED BY	Simon Wankuru	-							




FLOOR PLAN FOR EXISTING TOILET



**DIMENSION AND CONNECTION DETAILS
PLACEMENT OF EASTERN TOILETS**



TYPICAL TOILET INSTALLATION



MOUNT KITCHEN SINK

Note:

- All dimension are in cm, unless otherwise noted


- The existing toilets floors need to be demolished and reconstructed with new tiles and need new flash tanks for the WC's

- For the location of the toilets in the clinic site refers to site plan reference #9


act:onaïd

TASK & RESPOSIBILITIES		DATE	NO OF PAGES 5 6	PROVINCE	Ghor	SCALE	1:100	PROJECT SUB TITLE	Major maintenance of HCF WASH-Sector
SURVEYED BY	Gh. Farooq Ghafoori	23-05-2024		DISTRICT	Pasaband	START DATE	----	DRAWING TYPE	Toilet Plan
DRAWN BY	Gh. Farooq Ghafoori	04-06-2024		HCF NAME	Shinkot	END DATE	----	E	64° 51' 4.78"
REVIEWED BY	Hekmatullah Arefzai	-		HCF TYPE	CHC	PROJECT TITLE	FCDO-DAWAM	N	33° 41' 34.65"
APPROVED BY	Simon Wankuru	-							


Hand Washing Top View




Section C-C



Section B-B



Front View



act:onaid

TASK & RESPONSIBILITIES		DATE	NO OF PAGES 	PROVINCE	Ghor	SCALE	1:100	PROJECT SUB TITLE	Major maintenance of HCF WASH-Sector
SURVEYED BY	Gh. Farooq Ghafoori	23-05-2024		DISTRICT	Pasaband	START DATE	----	DRAWING TYPE	Tap-Station
DRAWN BY	Gh. Farooq Ghafoori	04-06-2024		HCF NAME	Shinkot	END DATE	----	E	64° 51' 4.78"
REVIEWED BY	Hekmatullah Arefzai	-		HCF TYPE	CHC	PROJECT TITLE	FCDO-DAWAM	N	33° 41' 34.65"
APPROVED BY	Simon Wankuru	-							